

**Technical datasheet  
neoTower® 5.0, 7.2**

**GHP HELLAS**  
AIR CONDITIONING WITH NATURAL GAS

Product designation	5.0	7.2
<b>Technical data</b>		
Rated output - electrical <sup>(1)</sup>	kW <sub>el</sub>	5,0
Rated output - thermal <sup>(2)</sup>	kW <sub>th</sub>	12,0
Power modulation - electrical	kW <sub>el</sub>	2,9 - 5,0
Power modulation - thermal	kW <sub>th</sub>	9,2 - 12,0
Energy input	kWh <sub>HI</sub>	15,82
Liquefied Petroleum gas input	kg/h	1,23
Liquefied Petroleum gas input	l/h	2,28
CHP coefficient		0,42
f Primary energy factor <sup>(3)</sup>		0,286
PES	%	34,0
ErP energy efficiency label <sup>(4)</sup>		A++
Sound pressure level L <sub>pA</sub> <sup>(5)</sup>	dB(A)	52
Sound power level L <sub>WA</sub>	dB(A)	67
Maintenance interval	op. hrs.	15.000
Oil interval	op. hrs.	7.500
<b>Efficiency ratios</b>		
Electrical efficiency ratio η <sub>el</sub>	%	31,6
Thermal efficiency ratio η <sub>th</sub>	%	75,7
Total efficiency ratio η <sub>total</sub>	%	107,3
<b>Heat extraction</b>		
Flow temperature ± 5 °C	°C	80
Return flow temperature ± 5 °C	°C	25-65
min./max. ambient temperature	°C	5/30
Pressure rating - water side	PN	3
<b>Electrical energy generation</b>		
Nominal voltage	V	400
Frequency	Hz	50
Nominal effective power PnG	kW <sub>el</sub>	5,0
Apparent power S <sub>E</sub> max	kVA	6,4
Nominal voltage UnG	V	400
Frequency	Hz	50
Cos φ uncompensated		0,78
Reactive power compensation <sup>(6)</sup>	kVar	2,87
Number of steps		1
Degree of choking or resonance frequency		-
Cos φ acc. to VDE-AR-N 4105 quadrants II, III <sup>(6)</sup>		0,95
Rated alternating current Ir	A	9,3
Rated alternating current Ir cos φ 1	A	7,2
Rated apparent power SrE	kVA	6,4
Short-circuit alternating current Alternator Ik"	A	72,5
Grid short circuit power with UnG Sk"	kVA	76,9
Start-up current Ik approx.	A	45
<b>Motor</b>		
Motor manufacturer	Toyota	Toyota
Number of cylinders	3	3
Displacement	l	1
Air-fuel ratio λ		1,6
Engine oil - RMB/ENGINE Oil	l	24

Product designation	5.0	7.2
<b>Generator</b>		
Generator manufacturer	EMOD	EMOD
Generator type	asynchron	asynchron
Motor start-up	provided	provided
Speed	1.550	1.550
<b>Supply and exhaust air</b>		
Combustion air requirement	32,34	29,48
Module ventilation flow rate	100,00	100,00
Total air requirement of module	132,34	129,48
Permissible counter-pressure of exhaust air system max. <sup>(7)</sup>	150	150
min./max. intake air temperature	5/30	5/30
Min. cross section without hydraulic resistance	250	250
<b>Flue gas</b>		
Flue gas temperature <sup>(8)</sup> / max.	50 / < 110	50 / < 110
Flue gas mass flow rate - damp	34	31
Flue gas volume flow - dry	28	25
Delivery pressure flue gas max.	500	500
Delivery pressure flue gas cascades max.	500	500
Delivery pressure max. for flue gas and exhaust air combination	150	150
Emissions Nox	< 240	< 240
<b>Dimensions &amp; weight</b>		
Dimensions of module L x W x H	1.205x613x1.102	1.205x613x1.102
Weight approx. (including operating resources)	444	444
<b>ErP-Label</b>		
ErP energy efficiency label <sup>(4)</sup>	A++	A++
ErP energy input <sup>(4)</sup>	17,56	25,62
ErP efficiency ratio - electrical $\eta_{el,HS}$ <sup>(4)</sup>	28,5	28,1
ErP efficiency ratio - thermal $\eta_{th,HS}$ <sup>(4)</sup>	68,2	70,5
ErP efficiency ratio - total $\eta_{total,HS}$ <sup>(4)</sup>	96,7	98,6
Room controller category <sup>(4)</sup>	2	2
$P_{designh}$ <sup>(4)</sup>	4,6	7,0
$Q_{HE}$ <sup>(4)</sup>	6.814	10.454
$P_{SB}$ electrical power requirement - standby <sup>(4)</sup>	0,03	0,03
Electrical power requirement - partial load <sup>(4)</sup>	0,20	0,19
$P_{el,max}$ Electrical power requirement - full load <sup>(4)</sup>	0,20	0,19
$P_{stby\_CHP}$ Thermal standing losses <sup>(4)</sup>	0,24	0,24
Electrical power requirement - standby <sup>(4)</sup>	0,03	0,03
$\eta_S = \eta_{son} - \sum(F1-F5)$ <sup>(4)</sup>	140,3	138,5
Net output - electrical	4,80	7,01

1) Performance data in accordance with ISO 3046/I-2002, tolerance 5%

2) Thermal performance data tolerance 8%

3)  $f_{pe}$ -current = 2.8 displacement mix per DIN V 1859, DIN V 4701-10, GEG (attachment 4 to § 22 section 1) valid from 11.2020

4) In accordance with EU Regulation 811/2013; 813/2013

5) Test bench measurement at 1 m interval in front of the CHP

6) Only when using the optional compensation (integrated in neoTower® 2.0, 3.3 and 4.0 / not required for neoTower® 5.0.0)

7) Exhaust air (without flue gas) does not have to be extracted "via the roof"

8) At a return temperature of 35 °C and optimum operating conditions, tolerance 5%

Product designation	5.0, 7.2
<b>Control cabinet</b>	Fully equipped for seamless CHP unit operation with all necessary measurement and control equipment in bivalent operation. Dimensions control cabinet 600x600x200 mm; Approx. weight: 30-33 kg Connection cable CHP control cabinet standard 3m
<b>Electrical connections</b>	Supply line to control cabinet: 5x4mm <sup>2</sup> Cu up to max. 50m (fuse 25 A slow blow) max. terminal area 16mm <sup>2</sup>
	Temperature sensor cable: min. 2-08 JY(ST)Y up to 15 m length (2x1,5 mm <sup>2</sup> up to 40 m length)
	Control cables pump: 3x1,5 mm <sup>2</sup> ; RJ45 Patch cable in CHP connector
<b>Reactive current compensation</b>	Fixed compensation without reactors (detuned)
	Operating voltage: 230 / 400 Volt, 50 Hz
	Integrated capacitor contactor
	Discharging of approx 40 seconds must be considered
	Limiting temperature -10°C up to +35°C (average 24 h) +40°C (short-term max.)
<b>Gas pressure [mbar / hPa]</b>	Steel housing 400x300x210mm (HxWxL)
	Gas resting pressure before gas regulator: 20 - 50 (for NG and LPG)
	Flow pressure ≥ 18 (for NG and LNG)
<b>Regulations and standards</b>	Complies with the pertinent EU Directives for CE certification
<b>Connections</b>	Gas: 1/2" internal thread
	Heating supply line: 1" ball valve / PN 3.0
	Heating return line: 1" ball valve / PN 3.0
	Flue gas: DN80
	Exhaust air: DN100; accepted back pressure to be considered!
	Note: It is important to ensure that all terminals are connected via a flexible connection, in order to ensure vibration isolation.
<b>Method of operation</b>	Residual pressure head secondary pump 0,7m
	Mains parallel without emergency power, heat operated
	Use of electricity: Own requirement and infeed into the grid of the energy supply company, optional electricity-optimised modulation
<b>Indicators and switches/buttons</b>	Heat usage automatically regulated in monovalent or bivalent operation with buffer tank; optionally heat-optimised modulation
	Operation of the internal control and monitoring programs via central control unit (touchscreen for quick access to important functions)
	Back-lit graphical colour display with visualised system diagram and indicators for: temperature memory, motor, return line, hot water, interior, oil, flue gas, indicator for current power, water pressure, operation hours, generated energy, maintenance instructions and error notifications
	Switches/buttons: master switch, Emergency stop, Electric vehicle (Efz) charging data button, maintenance button
<b>RMB/Report</b>	Global live data tracking visualised in installation diagram, individual password protection, data logging with daily, weekly, monthly and annual report in graphical format, remote maintenance, remote monitoring, evaluation and reporting
<b>Water quality</b>	Motor circuit: 40% glycol, 60% water per VDI Regulation 2035. Operational pressure warm: 2.0 bar. Operational pressure cold: 1.8 bar. Primary pressure expansion vessel cold: 1.0 bar. Heating circuit ("secondary circuit"): free from mechanical impurities and as a minimum in accordance with quality requirements of the Group 2, VDI Regulation 2035 Conductivity < 100µS/cm Water hardness < 1° dH 8.2 > pH-Wert < 9 Deviations cause severe damages!

Deviating values depending on environmental and operating conditions.

Technical modification, design deviation and errors excepted.